



**BATAAN PENINSULA STATE UNIVERSITY**

City of Balanga 2100 Bataan

Philippines

**PHYSICAL PLANT AND ENGINEERING SERVICES**

**BID BULLETIN FOR Supply and Installation of 250 KVA Brand-New Generator set for  
Administration Building at Main Campus**

1. Site Inspection certificate will be required as part of Bid documents.
2. Manual Transfer Switch must be built-in (remote) and Breaker type.
3. Cabling system will be underground with a minimum depth of 0.40m – 0.60m.

Prepared by:

**Engr. Mar O. Tapia**

Inspectorate, TWG for Infrastructure

**Ar. Roxette S. Umerez, uap**

Head, TWG for Infrastructure

Noted by:

**Dr. Alfredo D. Valentos, PME**

PPES Director